



TC-7183

Office  
H-4, First Floor, Mukund House,  
Azadpur, Delhi-110033  
T: 011-42118197 | M: +91 9871143705

Laboratory  
Plot No. 43, HSIIDC, Indir Estate,  
Raj, Sonapat, Haryana-131029  
T: 0130 4017631 | M: +91 9215515652

Email/Website  
info@metl.co.in  
metlson@yahoo.com  
www.metl.co.in

## TEST REPORT

ULR : TC718324000003453F

Page No. 1/1

Report No: METL/24-25/349/001	Report Date	18/12/2024
Issued To: Amrita Public School K-2, Sangam Vihar, New Delhi-110080	Customer Reference	APS/12/2024/1212
	Date of Sample Received	14/12/2024
	Date of test start	14/12/2024
	Date of Completion of test	17/12/2024
Sample Name	Water	
Sample Description	Drinking Water	
Sampling Location	-	
Sample Submitted By	Customer	Date of Sampling
Sampling Method	N.A.	Packing
Environmental Condition	22 Deg C	Sample Quantity
Group Name	Water	Discipline
		Chemical

### TEST RESULT

S.No.	Test Parameter	Unit	Observed Value	Requirement as per IS:10500-2012 RA 2018		Test Method
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
Chemical Test						
1	Colour	Hazen	<5	5.0 Max	15 Max	IS 3025(Pt-4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (part 5):2018
3	Turbidity	NTU	0.23	1.0 Max	5 Max	IS 3025(Pt-10):2023
4	pH Value (at 25°C)	--	6.57	6.5 - 8.5	No relaxation	IS 3025(Pt-11):2022
5	Total Hardness (as CaCO3)	mg/l	BDL(DL-2.0)	200 max	600 max	IS 3025(Pt-21):2009 RA 2019
6	Chloride (as Cl)	mg/l	12.0	250 Max	1000, Max	IS 3025(Pt-32):1988 RA 2019
7	Total Dissolved Solids	mg/l	82	500 Max	2000, Max	IS 3025(Pt-16):2023
8	Residual Free Chlorine	mg/l	Nil	0.2 Min	1.0 Min	IS 3025(Pt-26):2021
9	Iron (as Fe)	mg/l	0.08	1.0 Max	No Relaxation	IS 3025(Pt-53):2024
10	Fluoride (as F)	mg/l	0.11	1.0 Max	1.5 Max	APHA 24th Edi. 2023(4500 F)

Remarks : The submitted sample conforms to IS:10500-2012 RA 2018 w.r.t. above tests.

\*\*\*End of Report\*\*\*

Chhotu Ram  
Technical Manager  
Checked by

Mosin Ali  
Quality Manager  
Authorized Signatory

#### Terms & Conditions

- The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
- Total liability of our Lab. is limited to the invoiced amount.
- Samples will be destroyed after 30 Days from the date of issue of test report.
- This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.

Geeta Goyal  
Principal  
Amrita Public School

MANAGER  
AMRITA PUBLIC SCHOOL





**MUNICIPAL CORPORATION OF DELHI  
OFFICE OF THE DEPUTY HEALTH OFFICER  
PUBLIC HEALTH DEPARTMENT  
GREEN PARK, AURBINDO MARG,  
NEW DELHI-110016**

**NO. DHO/SZ/MCD/2024/D-2200**

**Dated: 7/2/2025**

**SCHOOL HEALTH CERTIFICATE**

It is certified that an inspection team headed by Sh. Heera LAL, Public Health Inspector from Public Health Department, South Zone inspected the Amrita Public School, located K-II/474, Sangam Vihar, New Delhi -110080. It was found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

**Deputy Health Officer  
South Zone  
M.C.D. Health Officer  
South Zone MCD**

**Copy to: -**

- **The Principal**  
Amrita Public School,  
K-II/474, Sangam Vihar,  
New Delhi -110080.
- **Office Copy**

*Geta Goyal*  
**Principal**  
**Amrita Public School**

*Singh*  
**MANAGER**  
**AMRITA PUBLIC SCHOOL**